

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



## Incentives for Energy Efficient Lighting (Effective March 21, 2022)

Energy Trust offers cash incentives to help you implement qualifying energy efficient lighting measures in eligible existing buildings. If you are interested in applying for incentives listed, contact us using the information located at the bottom of the page.

**To apply for lighting incentives, projects must (1) be submitted to Energy Trust by a Business Lighting trade ally for review and pre-qualification before any equipment purchase or installation activity begins; and (2) be pre-qualified for at least \$100 in incentive funding.**

**Only approved trade allies can offer Energy Trust's Business Lighting incentives to their customers for qualifying measures. All proposed lighting projects must be submitted by an enrolled Energy Trust Business Lighting trade ally in accordance with program participation requirements.**

It is important that you contact us for a project review before making purchases or taking other steps that may cause your project to be ineligible for incentives. Additional requirements apply. Program details, including incentives, are subject to change and budget availability. To learn more about Energy Trust's available offers and incentives, visit our website at [www.energytrust.org](http://www.energytrust.org).

## Lighting Project Specifications & Requirements

The following qualified product lists provide technical specifications for certain lighting products. Not all products listed qualify for Energy Trust incentives. To qualify for incentives, products must be new and measure installations must also pass Energy Trust cost-effectiveness criteria and meet other program requirements. Contact us for details.

- Proposed LED products must be on the appropriate Qualified Product List (QPL), as indicated below, and under the appropriate categorization to be eligible for incentives:
  - QPL for LED fixtures (except recessed canister downlights) and some LED retrofit lamps - Design Lights Consortium (DLC): [www.designlights.org/QPL](http://www.designlights.org/QPL)
  - QPL for LED recessed canister downlights & other (Certified Light Fixtures) – ENERGY STAR®: [www.energystar.gov/productfinder/product/certified-light-fixtures/](http://www.energystar.gov/productfinder/product/certified-light-fixtures/)
  - QPL for LED lamps (Certified Light Bulbs)– ENERGY STAR®: [www.energystar.gov/productfinder/product/certified-light-bulbs/](http://www.energystar.gov/productfinder/product/certified-light-bulbs/)
- Certain products with additional sizes or attributes outside of the QPL categories or specifications above may also qualify; Contact us with questions.
- References to "lighting tool" below means Energy Trust's Business Lighting Tool.

The following requirements apply to lighting projects:

- Energy Trust may require access to perform an on-site review of any project seeking Energy Trust incentives at any point during the project cycle in order to verify incentive eligibility. On-site reviews may be performed virtually at the request of the Participant or Energy Trust.
- Ballasts and drivers must be compatible with proposed lamps.
- Existing equipment must be removed and properly disposed of - not reused or sold for use elsewhere. Participants and their trade allies are responsible for the proper disposal/recycling of lamps and ballasts and must appropriately document such disposal as required by applicable law.
- Lighting measures may be reviewed in relation to Illuminating Engineering Society (IES) recommendations for minimum light levels and appropriate ratios for the space type and functions. If light levels appear to meet minimum IES recommendations and the specified lighting wattages exceed the measure specifications listed below, then any decision as to whether a specified measure qualifies for prescriptive or custom incentives rests solely with Energy Trust.
- Incentives for qualifying TLEDs and HID to LED screw-in retrofit lamp measures are available for K-12 Public Schools and Government Entity installations ONLY. Please contact us to discuss eligibility requirements for these incentives.
- Lighting measure installations that do not meet industry standards or other Energy Trust program requirements, as determined solely by Energy Trust, will not qualify for incentives. Final determination of eligibility for Energy Trust incentives rests with Energy Trust.
- Incentives for qualifying stand-alone prescriptive lighting controls measures (Section 6) will be calculated at a maximum of 100% of total eligible measure costs. Lighting measures with integrated LLLC or occupancy controls will be calculated at a maximum of 70% of the total eligible fixture and control measure costs combined. All remaining prescriptive measures will be calculated at a maximum of 50% of total eligible measure costs.

- Industrial horticultural grow operation project applicants must contact the program for detailed program requirements and eligibility review. See form PI490HL for additional information.
- Fixtures used for public roadways, including street lighting, may be eligible for incentives. See form PI190SL for additional information. Please contact us with questions.
- Qualifying products in lighting measure installations must be new; used equipment is not eligible for Energy Trust incentives.

<b>Section 1</b>	<b>Custom Lighting Controls and Lighting Upgrades</b>
<p>If you are considering a lighting retrofit or upgrade project and do not see your equipment listed on this information sheet identifying available prescriptive incentives in Sections 2 through 7, contact us to discuss whether your project (including lighting controls) may qualify for custom incentives from Energy Trust. <b>To be eligible for custom incentives, proposed custom lighting measures must be reviewed and pre-qualified in advance by Energy Trust and must also pass a custom cost-effectiveness analysis.</b></p> <ul style="list-style-type: none"> <li>• The maximum incentives provided by Energy Trust for any qualifying custom lighting measure are listed in this <b>Section 1</b> and will not exceed 50% of total eligible measure cost or Energy Trust’s established maximum incentive caps for projects.</li> <li>• Incentives for qualifying custom lighting controls measures will be calculated at a maximum of 50% total eligible measure cost not to exceed 20¢/annual kWh saved.</li> <li>• Incentives for qualifying custom lighting measures used for industrial horticultural grow operations will be calculated at a maximum of 50% total eligible measure cost not to exceed 18¢/annual kWh saved.</li> <li>• All qualifying lighting and lighting controls measures used for industrial horticultural grow operations, including qualifying linear fluorescent measures used in industrial horticultural grow operations will be calculated using the custom incentive application, as required by Energy Trust.</li> <li>• Incentives for all other qualifying custom lighting measures will be calculated at a maximum of 50% of total eligible measure costs not to exceed 15¢/annual kWh saved.</li> </ul> <p>Custom incentives are not available for certain proposed technologies such as manual controls, TLED, linear fluorescent, compact fluorescent (CFL), CFL to LED retrofit lamps, HID to LED retrofit lamps, mercury vapor (MV), incandescent, fluorescent induction, high pressure sodium (HPS), metal halide (MH), or photocell (exterior) sensors, unless specifically noted otherwise.</p>	

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

Section 2		LED Lamps replacing pin/screw-in incandescent or pin/screw-in CFL, unless noted.	
<i>Example application: Replace incandescent track head PAR lamp with screw-base LED replacement PAR lamp</i>			
Measure Description	Incentive		103L Analysis Drop Down Selections
LED directional/reflector lamp with integral driver, less than 20 watts (PAR/R/MR) and 40% minimum wattage savings per lighting tool measure line required	\$6	per proposed lamp	LED_Lamps   LED lamp <20W (PAR/R/MR)
LED directional/reflector lamp with integral driver, 20 watts or greater (PAR/R/MR) and 40% minimum wattage savings per lighting tool measure line required	\$9	per proposed lamp	LED_Lamps   LED lamp 20W or greater (PAR/R/MR)
LED decorative (candelabra or globe) and 40% minimum wattage savings per lighting tool measure line required	\$3	per proposed lamp	LED_Lamps   LED small screw-base candelabra lamp
			LED_Lamps   LED globe screw-in lamp
LED omni-directional (A-Lamp or similar) and 40% minimum wattage savings per lighting tool measure line required (baseline lamp is 150W or less)	\$3	per proposed lamp	LED_Lamps   LED A-Lamp
Pin-CFL to pin base LED and 40% minimum wattage savings per lighting tool measure line required	\$2	per proposed lamp	LED_Lamps   CFL to pin base LED
<ul style="list-style-type: none"> <li>When installing pin base LEDs, Business Lighting trade ally should enter manufacturer stated system wattage, if available, in the proposed lamp wattage section in the Lighting Tool. If system wattage is not reasonable to obtain, manufacturer stated lamp wattage is acceptable (otherwise DLC QPL wattage will be used).</li> </ul>			

# Business Lighting Incentives

Existing Buildings, Production Efficiency and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

Section 3 Interior LED Fixtures with and without luminaire level lighting controls (LLLCs)											
<ul style="list-style-type: none"> <li>Retrofit-kits and new fixture options, ballasts &amp; lamp sockets removed</li> </ul>											
		<i>Example application: T12 four-lamp recessed troffer to high performance LED retrofit kit.</i>									
Measure Description	Incentive for fixtures only	Incentive for fixtures with LLLC controls	103L Analysis Drop Down Selections								
Recessed Canister Downlight LED kit or LED fixture replacing any existing technology and 40% minimum wattage savings per lighting tool measure line required	\$12	NA	<table border="1"> <tr> <td>LED_Interior_Fixtures</td> <td>Interior Recessed Canister Downlight LED</td> </tr> </table>	LED_Interior_Fixtures	Interior Recessed Canister Downlight LED						
LED_Interior_Fixtures	Interior Recessed Canister Downlight LED										
LED fixture or kit, 25W or less and 40% minimum wattage savings per lighting tool measure line required	\$25	\$50	<table border="1"> <tr> <td>LED_Interior_Fixtures</td> <td>LED fixture or kit, 25W or less</td> </tr> <tr> <td>LLLC</td> <td>LLLC on LED fixture or kit, 25W or less</td> </tr> </table>	LED_Interior_Fixtures	LED fixture or kit, 25W or less	LLLC	LLLC on LED fixture or kit, 25W or less				
LED_Interior_Fixtures	LED fixture or kit, 25W or less										
LLLC	LLLC on LED fixture or kit, 25W or less										
LED fixture or kit, 26-57W and 40% minimum wattage savings per lighting tool measure line required	\$40	\$80	<table border="1"> <tr> <td>LED_Interior_Fixtures</td> <td>LED fixture or kit, 26-39W</td> </tr> <tr> <td>LED_Interior_Fixtures</td> <td>LED fixture or kit, 40-57W</td> </tr> <tr> <td>LLLC</td> <td>LLLC on LED fixture or kit, 26-39W</td> </tr> <tr> <td>LLLC</td> <td>LLLC on LED fixture or kit, 40-57W</td> </tr> </table>	LED_Interior_Fixtures	LED fixture or kit, 26-39W	LED_Interior_Fixtures	LED fixture or kit, 40-57W	LLLC	LLLC on LED fixture or kit, 26-39W	LLLC	LLLC on LED fixture or kit, 40-57W
LED_Interior_Fixtures	LED fixture or kit, 26-39W										
LED_Interior_Fixtures	LED fixture or kit, 40-57W										
LLLC	LLLC on LED fixture or kit, 26-39W										
LLLC	LLLC on LED fixture or kit, 40-57W										
LED fixture or kit, 58-100W and 40% minimum wattage savings per lighting tool measure line required	\$45	\$85	<table border="1"> <tr> <td>LED_Interior_Fixtures</td> <td>LED fixture or kit, 58-100W</td> </tr> <tr> <td>LLLC</td> <td>LLLC on LED fixture or kit, 58-100W</td> </tr> </table>	LED_Interior_Fixtures	LED fixture or kit, 58-100W	LLLC	LLLC on LED fixture or kit, 58-100W				
LED_Interior_Fixtures	LED fixture or kit, 58-100W										
LLLC	LLLC on LED fixture or kit, 58-100W										
<ul style="list-style-type: none"> <li>Each incentive in Section 3 is per proposed fixture</li> <li>Existing single-lamp fluorescent fixture applications must use custom incentive calculation as described in Section 1 "Custom Incentives."</li> <li>Fixtures using TLEDs are not eligible for incentives in this section.</li> <li>LED fixtures &gt;100W, excluding high-bay and low-bay, can apply under Section 1. For high-bay and low-bay LED fixtures, refer to Section 4.</li> <li>Unique architectural fixtures such as chandeliers or decorative art fixtures can apply under Section 1.</li> <li>For industrial process and horticultural lighting incentives, refer to form PI490HL.</li> <li>Luminaire Level Lighting Control (LLLC) systems must meet the DLC Networked Lighting Control System Technical Requirements NLCv5.0.                             <ul style="list-style-type: none"> <li>LLLC luminaires or kits require a networked occupancy sensor and ambient light sensor directly integrated or embedded into the luminaire or kit during the manufacturing process</li> <li>LLLC systems must be programmed as follows:                                     <ul style="list-style-type: none"> <li>Task Tuning: Required with High End Trim at 80% or lower;</li> <li>Daylighting: Required where floor area is substantially illuminated by daylight;   <ul style="list-style-type: none"> <li>see ASHRAE 90.1-2019 for more guidance on what constitutes a daylight area;</li> </ul> </li> <li>Occupant sensing: Required with a time delay of 10 minutes or less   <ul style="list-style-type: none"> <li>Manual On encouraged where it does not endanger safety or security.</li> </ul> </li> </ul> </li> </ul> </li> </ul>											

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

Section 4		High-Bay / Low-Bay fixtures and non-screw-in retrofit kits with and without luminaire level lighting controls (LLLCs)		
<i>Example application: Replace 400W MH high-bay fixture with a 150W LED high-bay fixture</i>				
Measure Description	Incentive for fixtures without advanced controls	Incentive for fixtures with LLLC controls	103L Analysis Drop Down Selections	
LED High-Bay or Low-Bay, 40-90W and 40% minimum wattage savings per lighting tool measure line required	\$100	\$155	LED_High_Bay	LED High-Bay or Low-Bay, 40-90W
			LLLC	LLLC on LED High-Bay or Low-Bay, 40-90W
LED High-Bay or Low-Bay, 91-140W and 40% minimum wattage savings per lighting tool measure line required	\$150	\$215	LED_High_Bay	LED High-Bay or Low-Bay, 91-140W
			LLLC	LLLC on LED High-Bay or Low-Bay, 91-140W
LED High-Bay or Low-Bay, 141-299W and 40% minimum wattage savings per lighting tool measure line required	\$175	\$250	LED_High_Bay	LED High-Bay or Low-Bay, 141-299W
			LLLC	LLLC on LED High-Bay or Low-Bay, 141-299W
LED High-Bay or Low-Bay, 300W or greater and 40% minimum wattage savings per lighting tool measure line required	\$250	\$355	LED_High_Bay	LED High-Bay or Low-Bay, 300W or greater
			LLLC	LLLC on LED High-Bay or Low-Bay, 300W or greater
<ul style="list-style-type: none"> <li>Each incentive in Section 4 is per proposed fixture.</li> <li>Proposed fixtures must be QPL listed in the High-Bay category.</li> <li>Projects using TLEDs or HID to LED screw-in lamps do not qualify for incentives in this section.</li> <li>Luminaire Level Lighting Control (LLLC) systems must meet the DLC Networked Lighting Control System Technical Requirements NLCv5.0.                             <ul style="list-style-type: none"> <li>LLLC luminaires or kits, require a networked occupancy sensor and ambient light sensor directly integrated or embedded into the luminaire or kit during the manufacturing process</li> <li>LLLC systems must be programmed as follows:                                     <ul style="list-style-type: none"> <li>Task Tuning: Required with High End Trim at 80% or lower;</li> <li>Daylighting: Required where floor area is substantially illuminated by daylight;   <ul style="list-style-type: none"> <li>see ASHRAE 90.1-2019 for more guidance on what constitutes a daylight area;</li> </ul> </li> <li>Occupant sensing: Required with a time delay of 10 minutes or less   <ul style="list-style-type: none"> <li>Manual On encouraged where it does not endanger safety or security.</li> </ul> </li> </ul> </li> </ul> </li> </ul>				

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

<b>Section 5</b>	<b>Exterior Pole/Arm-mounted Area Luminaires, Exterior Wall-mounted Area Luminaires, Parking Garage Luminaires, Fuel Pump Canopy, Exterior Downlights, and Architectural Flood/Spot Lighting with and without luminaire level lighting controls (LLLCs)</b> <ul style="list-style-type: none"> <li>• Non screw-in only</li> </ul>
------------------	---


*Example application: Replace 70 watt HID wall pack with 30 watt LED wall pack*

Measure Description	Incentive for fixtures without advanced controls	Incentives for fixtures with LLLC controls	103L Analysis Drop Down Selections	
Exterior Recessed Canister Downlight LED kit or new LED fixture replacing any existing technology and 40% minimum wattage savings per lighting tool measure line required	\$12	NA	LED_Exterior_Fixtures	Exterior Recessed Canister Downlight LED
Exterior LED fixture, 20W or less and 40% minimum wattage savings per lighting tool measure line required	\$30	\$50	LED_Exterior_Fixtures	Exterior LED fixture, 20W or less
			LLLC	LLLC on Exterior LED fixture, 20W or less
Exterior LED fixture, 21-40W and 40% minimum wattage savings per lighting tool measure line required	\$45	\$85	LED_Exterior_Fixtures	Exterior LED fixture, 21-40W
			LLLC	LLLC on Exterior LED fixture, 21-40W
Exterior LED fixture, 41-90W and 40% minimum wattage savings per lighting tool measure line required	\$90	\$140	LED_Exterior_Fixtures	Exterior LED fixture, 41-90W
			LLLC	LLLC on Exterior LED fixture, 41-90W
Exterior LED fixture, 91-140W and 40% minimum wattage savings per lighting tool measure line required	\$130	\$185	LED_Exterior_Fixtures	Exterior LED fixture, 91-140W
			LLLC	LLLC on Exterior LED fixture, 91-140W
Exterior LED fixture, 141-299W and 40% minimum wattage savings per lighting tool measure line required	\$155	\$220	LED_Exterior_Fixtures	Exterior LED fixture, 141-299W
			LLLC	LLLC on Exterior LED fixture, 141-299W"
Exterior LED fixture, 300W or greater and 40% minimum wattage savings per lighting tool measure line required	\$235	\$320	LED_Exterior_Fixtures	Exterior LED fixture, 300W or greater
			LLLC	LLLC on Exterior LED fixture, 300W or greater

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L




- Each incentive in Section 5 is per proposed fixture.
- Fixtures using TLEDs are not eligible for incentives in this section.
- Luminaire Level Lighting Control (LLLC) systems must meet the DLC Networked Lighting Control System Technical Requirements NLCv5.0.
- LLLC luminaires or kits, require a networked occupancy sensor and ambient light sensor directly integrated or embedded into the luminaire or kit during the manufacturing process

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



Section 6		Lighting Controls: Custom control or system	
<i>Example application: Integral warehouse aisle occupancy sensor mounted on T5, LED, or T8 High Bay fixture</i>			
Measure Description	Incentive		103L Controls Tabs Drop Down Selections
Custom lighting controls or systems not listed in this Section 6 below, or in the Sections 3 through 5 LLLC descriptions above, can be submitted for review as a proposed custom measure	See Section 1 "Custom Incentives"		<div style="border: 1px solid black; padding: 2px;">Custom control or system</div> <div style="border: 1px solid black; padding: 2px;">Hard-Wired Occupancy Sensor, ceiling/corner/surface mount, 100W or greater</div>
Interior Vacancy Sensor (manual-on version) Wall switch Control loads 30W or greater	\$25	per proposed sensor	<div style="border: 1px solid black; padding: 2px;">Wall Switch Vacancy Sensor, 30W or greater</div>
Interior Occupancy Sensor (automatic-on version) Wall switch Control loads 30W or greater	\$25	per proposed sensor	<div style="border: 1px solid black; padding: 2px;">Wall Switch Occupancy Sensor, 30W or greater</div>
Interior Occupancy Sensor Fixture mount Control loads 30W or greater	\$40	per proposed sensor	<div style="border: 1px solid black; padding: 2px;">Occupancy Sensor, fixture mount, 30W or greater</div>
Interior Wireless Occupancy Sensor Ceiling, corner, or surface (including wall) mount Control loads 100W or greater	\$50	per proposed sensor	<div style="border: 1px solid black; padding: 2px;">Wireless Occupancy Sensor, ceiling/corner/surface mount, 100W or greater</div>
Exterior Occupancy Sensor Fixture or pole mounted (wired or wireless) Control loads 40W and greater Proposed fixture wattage reduction 50% or greater in unoccupied mode using dimming, step, bi-level, or on/off functionality.	\$25	per proposed sensor	<div style="border: 1px solid black; padding: 2px;">Exterior Occupancy Sensor, fixture or pole mount, 40W or greater</div>
<ul style="list-style-type: none"> <li>Wireless occupancy sensors mounted separately from the fixture and typically installed on/in the ceiling/corner/surface location and may control multiple lighting fixtures are eligible. Wireless is defined as a device whose "control signal" is not transmitted over a wire to and from the sensor and fixture(s); power can be battery/self-powered or over a wire, fixtures can have wired receivers.</li> <li>Manual wall switch (on/off), manual dimmers, simple timeclock controls, simple exterior photocell sensors, and existing controls are not eligible.</li> </ul> <p>The following control types are not included as prescriptive measures. These may be suited to custom projects. (see Section 1).</p> <ul style="list-style-type: none"> <li>Advanced lighting controls such as daylight dimming, Direct digital controls (DDC)/Energy Management Systems (EMS), non-integrated NLCs or LLLC measures not controlling eligible Interior, High-Bay/Low-Bay and Exterior fixtures.</li> <li>Hardwired occupancy sensors mounted separately from the fixture and typically installed on or in a ceiling/corner/surface location and may control multiple lighting fixtures.</li> <li>Controls on lighting fixtures that do not meet wattage thresholds.</li> </ul>			



# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

Section 7	LED Cooler/Freezer Lighting • LED fixtures must be listed as case lighting, on the DLC product list		
LED Display Case Lighting	Measure Description	Incentive	
Motion Sensor, on Low Power LED	<ul style="list-style-type: none"> <li>On LED cases, side bar (single)</li> <li>Reach-in or open display cases<sup>1</sup></li> </ul>	\$1.60	per proposed linear ft of fixture
Motion Sensor, on High Power LED	<ul style="list-style-type: none"> <li>On LED cases, mullion bar (double)</li> <li>Reach-in or open display cases<sup>1</sup></li> </ul>	\$2.40	per proposed linear ft of fixture
Single Row T8 Low Power LED (Medium Temp Case)	<ul style="list-style-type: none"> <li>Replace T8 with LED side bar (single)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$8	per proposed linear ft of fixture
Single Row T12 Low Power LED (Medium Temp Case)	<ul style="list-style-type: none"> <li>Replace T12 with LED side bar (single)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$8	per proposed linear ft of fixture
Double Row T8 High Power LED (Medium Temp Case)	<ul style="list-style-type: none"> <li>Replace T8 with LED mullion (double)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture
Double Row T12 High Power LED (Medium Temp Case)	<ul style="list-style-type: none"> <li>Replace T12 with LED mullion (double)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture
Single Row T12 Low Power LED (Medium Temp Case or Low Temp Case)	<ul style="list-style-type: none"> <li>Replace T12 with LED side bar (single)</li> <li>On the canopy or lip of open display cases<sup>2</sup></li> </ul>	\$8	per proposed linear ft of fixture
Double Row T8 High Power LED (Medium Temp Case or Low Temp Case)	<ul style="list-style-type: none"> <li>Replace T8 with LED mullion (double)</li> <li>On the canopy or lip of open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture
Double Row T12 High Power LED (Medium Temp Case or Low Temp Case)	<ul style="list-style-type: none"> <li>Replace T12 with LED mullion (double)</li> <li>On the canopy or lip of open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture
Single Row T8 Low Power LED (Low Temp Case)	<ul style="list-style-type: none"> <li>Replace T8 with LED side bar (single)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$8	per proposed linear ft of fixture
Single Row T12 Low Power LED (Low Temp Case)	<ul style="list-style-type: none"> <li>Replace T12 with LED side bar (single)</li> <li>Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$8	per proposed linear ft of fixture

# Business Lighting Incentives

Existing Buildings, Production Efficiency  
and Multifamily Buildings

Program Information | 190L



////////////////////////////////////

LED Display Case Lighting	Measure Description	Incentive	
Double Row T8 High Power LED (Low Temp Case)	<ul style="list-style-type: none"> <li>• Replace T8 with LED mullion (double)</li> <li>• Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture
Double Row T12 High Power LED (Low Temp Case)	<ul style="list-style-type: none"> <li>• Replace T12 with LED mullion (double)</li> <li>• Inside reach-in or open display cases<sup>2</sup></li> </ul>	\$16	per proposed linear ft of fixture

<sup>1</sup> Motion Sensors – LED Case Lighting Requirements:

- Incentives are based on linear feet of LED fixture controlled by the motion sensor
- Install a motion sensor controlling permanently installed LED lighting in refrigerated reach-in case(s)
- Incentive and energy savings values vary based on the controlled LED luminaire power (low or high):
  - Low power luminaire is defined as one that uses <= 4.5W/ft of fixture (single)
  - High power luminaire is defined as one using > 4.5W to < 8.5W/ft of fixture (double)

<sup>2</sup> LED Case Lighting Requirements:

- Incentives paid are based on linear feet of installed LED fixture.
- Only LED fixtures on the Design Lights Consortium product list for case lighting, under indoor luminaires, are eligible.